




# Model for Waste Transfer Line System of Salt Processing Program

A decorative graphic consisting of two dark red lines intersecting at a central point, forming a crosshair shape.

**Washington Savannah River Corp.  
Systems Engineering  
Bob Chang**

## Tailored Salt Treatment Approach



\*Salt wastes must be segregated to enable multiple treatment paths

May 2003

# Salt Processing Technology of Choice

---

- **Actinide Removal Process (ARP):**
  - Use monosodium titanate (MST) strike to absorb the strontium and actinides then following filtration to remove the MST and sludge solids. Filtrate to CSSX or Saltstone.
  - To treat “low in cesium but contains actinides” waste and “high curie with actinide salt” waste.

# CSSX Technology

---

- **Caustic Side Solvent Extraction (CSSX)**
  - **Three stages**
    - **Extraction Stage,**
    - **Scrub Stage,**
    - **Strip Stage.**
  - **Clean raffinate stream to Saltstone for disposal.**
  - **Cs-Strip effluent in aqueous phase to DWPF for vitrification.**

# CSSX Technology

---


- **Scrub Stage: Following cesium extraction, the solvent is scrubbed with dilute nitric acid to remove other soluble salts from the solvent stream to aqueous phase.**

# CSSX Technology

---


- **Strip Stage: Solvent contacted with a very dilute nitric acid stream containing a small quantity of cold cesium to transfer the cesium to the acid stream.**
- **Solvent recycled.**

# Process Flow Sheet Summary




# Project Overview

## LWD Salt Processing



# 96H, 512-S & SWPF OPS



# Problem Statement

---

- **A recent program risk assessment identified several waste transfer lines as potential process bottlenecks. Two areas of risk were identified: (1) Bi-directional flow in a transfer line and (2) Multi-process mutual use of a transfer line. Both the transfer line “bi-directional flow” and “mutual use” scenarios can create usage conflicts, thereby limiting the ability of the various waste transfer systems to make transfers between processes.**

# Objectives of Model

---


- **Objective**
  - **Evaluate the risk of using Bi-Directional Flow Transfer Lines and Mutual Use Transfer Lines by studying the impact of utilizing these transfer lines on processing rates and attainments for Actinide Removal Process (ARP), Modular CSSX Unit (MCU), Salt Waste Processing Facility (SWPF), and Defense Waste Processing Facility (DWPF).**

# Project Requirements

---

- **Target**
  - ARP + SWPF
    - ARP = 1 Mgal/yr
    - SWPF = 6 Mgal/yr
  - SWPF (no ARP)
    - 7 Mgal/yr
- **Minimum Throughput Requirement**
  - SWPF process > 3.0 Mgal/yr fresh waste

# Nuclear Waste Management System in SRS



# Parameters for Different Cases

| Case                              | 1      | 2         | 3         | 4                   | 5         | 6         | 7         | 8         | 9         | 10        |
|-----------------------------------|--------|-----------|-----------|---------------------|-----------|-----------|-----------|-----------|-----------|-----------|
| CSSX Rate (SWPF)                  | 17 gpm | 21.29 gpm | 21.29 gpm | 21.29 gpm           | 21.29 gpm | 21.29 gpm | 21.29 gpm | 21.29 gpm | 21.29 gpm | 21.29 gpm |
| Tank 50 Available                 | Yes    | No        | Yes       | No                  | Yes       | Yes       | Yes       | Yes       | Yes       | Yes       |
| Tank 49 Feed and Bleed            | No     | No        | Yes       | No                  | No        | No        | No        | No        | Yes       | Yes       |
| New Tank in Saltstone for DSS     | No     | No        | No        | Yes<br>0.12<br>Mgal | No        | No        | No        | No        | No        | No        |
| Each SRAT batch fills x canisters | 6      | 6         | 6         | 6                   | 5.5       | 6         | 5.5       | 6         | 6         | 5.5       |
| Canister pour time                | 26 hr  | 26 hr     | 26 hr     | 26 hr               | 26 hr     | 26 hr     | 22 hr     | 26 hr     | 26 hr     | 26 hr     |
| Strike Time                       | 24 hr  | 24 hr     | 24 hr     | 24 hr               | 24 hr     | 24 hr     | 24 hr     | N/A       | N/A       | N/A       |
|                                   | 12 hr  | 12 hr     | 12 hr     | 12 hr               | 12 hr     | 12 hr     | 12 hr     | 12 hr     | 12 hr     | 12 hr     |
| ARP Running                       | Yes    | Yes       | Yes       | Yes                 | Yes       | Yes       | Yes       | No        | No        | No        |
| SWPF Throughput                   | 3.17   | 2.97      | 4.08      | 3.7                 | 4.03      | 3.79      | 4.10      | 4.68      | 5.28      | 5.15      |
| ARP Throughput                    | 0.79   | 0.78      | 0.75      | 0.7                 | 0.72      | 0.7       | 0.74      | 0         | 0         | 0         |
| ARP + SWPF                        | 3.96   | 3.75      | 4.8       | 4.4                 | 4.7       | 4.5       | 4.84      | 4.68      | 5.28      | 5.15      |

# Parameters for Different Cases

| Case                              | 1      | 2         | 3         | 4                   | 5         | 6         | 7         | 8         | 9         | 10        |
|-----------------------------------|--------|-----------|-----------|---------------------|-----------|-----------|-----------|-----------|-----------|-----------|
| CSSX Rate (SWPF)                  | 17 gpm | 21.29 gpm | 21.29 gpm | 21.29 gpm           | 21.29 gpm | 21.29 gpm | 21.29 gpm | 21.29 gpm | 21.29 gpm | 21.29 gpm |
| Tank 50 Available                 | Yes    | No        | Yes       | No                  | Yes       | Yes       | Yes       | Yes       | Yes       | Yes       |
| Tank 49 Feed and Bleed            | No     | No        | Yes       | No                  | No        | No        | No        | No        | Yes       | Yes       |
| New Tank in Saltstone for DSS     | No     | No        | No        | Yes<br>0.12<br>Mgal | No        | No        | No        | No        | No        | No        |
| Each SRAT batch fills x canisters | 6      | 6         | 6         | 6                   | 5.5       | 6         | 5.5       | 6         | 6         | 5.5       |
| Canister pour time                | 26 hr  | 26 hr     | 26 hr     | 26 hr               | 26 hr     | 26 hr     | 22 hr     | 26 hr     | 26 hr     | 26 hr     |
| Strike Time                       | 24 hr  | 24 hr     | 24 hr     | 24 hr               | 24 hr     | 24 hr     | 24 hr     | N/A       | N/A       | N/A       |
|                                   | 12 hr  | 12 hr     | 12 hr     | 12 hr               | 12 hr     | 12 hr     | 12 hr     | 12 hr     | 12 hr     | 12 hr     |
| ARP Running                       | Yes    | Yes       | Yes       | Yes                 | Yes       | Yes       | Yes       | No        | No        | No        |
| SWPF Throughput                   | 3.17   | 2.97      | 4.08      | 3.7                 | 4.03      | 3.79      | 4.10      | 4.68      | 5.28      | 5.15      |
| ARP Throughput                    | 0.79   | 0.78      | 0.75      | 0.7                 | 0.72      | 0.7       | 0.74      | 0         | 0         | 0         |
| ARP + SWPF                        | 3.96   | 3.75      | 4.8       | 4.4                 | 4.7       | 4.5       | 4.84      | 4.68      | 5.28      | 5.15      |

# Parameters for Different Cases

| Case                              | 1      | 2         | 3         | 4                   | 5         | 6         | 7         | 8         | 9         | 10        |
|-----------------------------------|--------|-----------|-----------|---------------------|-----------|-----------|-----------|-----------|-----------|-----------|
| CSSX Rate (SWPF)                  | 17 gpm | 21.29 gpm | 21.29 gpm | 21.29 gpm           | 21.29 gpm | 21.29 gpm | 21.29 gpm | 21.29 gpm | 21.29 gpm | 21.29 gpm |
| Tank 50 Available                 | Yes    | No        | Yes       | No                  | Yes       | Yes       | Yes       | Yes       | Yes       | Yes       |
| Tank 49 Feed and Bleed            | No     | No        | Yes       | No                  | No        | No        | No        | No        | Yes       | Yes       |
| New Tank in Saltstone for DSS     | No     | No        | No        | Yes<br>0.12<br>Mgal | No        | No        | No        | No        | No        | No        |
| Each SRAT batch fills x canisters | 6      | 6         | 6         | 6                   | 5.5       | 6         | 5.5       | 6         | 6         | 5.5       |
| Canister pour time                | 26 hr  | 26 hr     | 26 hr     | 26 hr               | 26 hr     | 26 hr     | 22 hr     | 26 hr     | 26 hr     | 26 hr     |
| Strike Time                       | 24 hr  | 24 hr     | 24 hr     | 24 hr               | 24 hr     | 24 hr     | 24 hr     | N/A       | N/A       | N/A       |
|                                   | 12 hr  | 12 hr     | 12 hr     | 12 hr               | 12 hr     | 12 hr     | 12 hr     | 12 hr     | 12 hr     | 12 hr     |
| ARP Running                       | Yes    | Yes       | Yes       | Yes                 | Yes       | Yes       | Yes       | No        | No        | No        |
| SWPF Throughput                   | 3.17   | 2.97      | 4.08      | 3.7                 | 4.03      | 3.79      | 4.10      | 4.68      | 5.28      | 5.15      |
| ARP Throughput                    | 0.79   | 0.78      | 0.75      | 0.7                 | 0.72      | 0.7       | 0.74      | 0         | 0         | 0         |
| ARP + SWPF                        | 3.96   | 3.75      | 4.8       | 4.4                 | 4.7       | 4.5       | 4.84      | 4.68      | 5.28      | 5.15      |

### Approximate Transfer Line Holdup Volumes

#### Approximate Holdup Volume

Trapped Volume in the transfer lines at approx. EL. 306.


1 ft. 3" schd. 40 SS core pipe = ~0.384 gallons

PCP341 to 512-S =  $\sim 935\text{ft} \times 0.384 = \sim 360$  gallons

PCP4 to SWPF =  $\sim 2797\text{ft} \times 0.384 = \sim 1074$  gallons

Total Holdup Volume =  $\sim 1438$  gallons

Total Line Volume VB-49 to SWPF =  $\sim 1446$  gallons



~360\_ Gallons Hold Up in Line PCP341

~834\_ Gallons Hold Up in Line PCP4

# Deficiencies Identified

---

- **The model identified deficiencies in existing operational and flushing strategy for the Waste Transfer Line project. Based on the old operational and flushing strategy, two tanks will overflow due to the additions of trapped flushing water in the transfer line into the tanks.**

# Conclusions

---

- **It is unlikely that the Target Average Annual Rate of 7Mgal/year Can Be Achieved, Due to Close Coupling of SWPF with DWPF and Other Facilities.**
- **Building Dedicated Transfer Line is Not the Best Use of Resources.**
- **Provide Inputs to Interim Processing Plan.**
- **Very little advantage to process ARP after SWPF.**
- **Based on the modeling results, both WSRC and DOE has made a business decision not to run ARP post SWPF startup.**